



NOTES:

1. ANY PIPE DEFLECTED MORE THAN 2% SHALL BE REJECTED AND REPLACED AT CONTRACTOR'S EXPENSE.
2. INSTALLATION SHALL BE AS PER MANUFACTURER'S RECOMMENDATIONS INCLUDING ITEMS AS DETAILED IN INSTALLATION MANUAL FOR CORRUGATED STEEL DRAINAGE STRUCTURES.

STORM SEWER JOINT WRAP DETAIL

NOT TO SCALE

CITY OF TOMBALL ENGINEERING & PLANNING DEPARTMENT	
STORM SEWER JOINT WRAP CONSTRUCTION DETAIL	
APPROVED BY COT:	
ENGINEERING & PLANNING DEPARTMENT EFFECTIVE SEPTEMBER 7, 2017	
SHEET 001 OF 001	DWG NO: COT STM-25