

Section 02951

PAVEMENT REPAIR AND RESURFACING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Repairing and resurfacing streets, highways, driveways, sidewalks, and other pavements that have been cut, broken, or otherwise damaged during construction.

1.02 MEASUREMENT AND PAYMENT

- A. Unit Prices.
 - 1. No separate payment will be made for pavement repair and resurfacing under this Section. Include payment in unit price for work in appropriate sections.
 - 2. Refer to Section 01270 - Measurement and Payment for other unit price procedures.
- B. Stipulated Price (Lump Sum). If Contract is Stipulated Price Contract, payment for work in this section is included in total Stipulated Price.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Sub grade:
 - 1. Provide backfill material as required by applicable excavation and fill sections (Sections 02315 through 02319) and Section 02330 - Embankment.
 - 2. Provide material for stabilization as required by applicable portions of Section 02336 - Lime Stabilized Sub grade, Section 02337 - Lime/Fly-Ash Stabilized Sub grade, and Section 02338 - Portland Cement Stabilized Sub grade.
- B. Base: Provide base material as required by applicable portions of Section 02711 - Hot Mix Asphaltic Base Course, Section 02712 - Cement Stabilized Base Course, Section 02713 - Crushed Concrete Base Course, and Section 02716 - Cement Stabilized Sand Base.
- C. Pavement: Provide paving materials as required by applicable portions of Section 02741 - Asphaltic Concrete Pavement, Section 02751- Concrete Paving, Section 02754 - Concrete Driveways, and Section 02771 - Curb, Curb and Gutter, and Headers, and Section 02775 - Concrete Sidewalks.

PART 3 EXECUTION

3.01 PREPARATION

- A. Notify City as provided in Paragraph 3.13.2.1 of Document 00800 prior to commencement of excavation in pavement for which an Excavation in Public Way permit has been obtained.
- 2. Conform to requirement of Section 02221 - Removing Existing Pavements and Structures, for removals.
- C. Saw cut pavement 18 inches wider than width of trench needed to install utilities unless otherwise indicated on Drawings.
- D. When removing pavement to existing deformed metal strip (i.e. dummy joint), saw cut pavement minimum 2 inches deep on opposite side of deformed metal strip. Place saw joint far enough behind deformed metal strip to obtain continuously straight joint. Remove damaged portion of deformed metal strip as required to provide proper joint. Saw cut and remove metal strip before placement of new concrete pavement.
- E. Protect edges of existing pavement to remain from damage during removals, utility placement, backfill, and paving operations. For concrete pavement, leave and protect minimum 18 inches of undisturbed Sub grade on each side of trench to support replacement slab.
- F. Dowel in existing pavement where no reinforcement is found or is broken due to construction activities. Unless otherwise directed by City Engineer, provide No. 6 bars 24 inches long, drilled and embedded 8 inches into center of existing slab with 'PO-ROC' epoxy grout or approved equal. Space dowels to match new pavement reinforcement spacing.
- G. Provide transitional paving and earthwork as required to tie proposed pavement to existing pavement when unable to dowel new pavement into existing pavement.

3.02 INSTALLATION

- A. Parking Areas, Service Drives, Driveways, and Sidewalks: Replace with material equal to or better than existing or as indicated on Drawings. Conform to applicable requirements of sections referenced in Paragraph 2.01, Materials.
- B. Street Pavements and Curbs, Curbs and Gutters: Replace sub grade, base, and surface course with like materials or as indicated on Drawings and City of Tomball Standard Detail 02951.01. Curbs and curbs and gutters shall match existing. Conform to requirements of sections referenced in Paragraph 2.01, Materials.

- C. For concrete pavement, install size and length of reinforcing steel and pavement thickness indicated on Drawings and City of Tomball Standard Detail 02951.01. Place types and spacing of joints to match existing or as indicated on Drawings.
- D. Where existing pavement consists of concrete pavement with asphaltic surfacing, resurface with minimum 2-inch depth asphaltic pavement.
- E. Repair state highway and county crossings in accordance with TxDOT permit or county requirements as appropriate and within 1 week after utility work is installed.

3.03 WASTE MATERIAL DISPOSAL

- A. Dispose of waste material in accordance with requirements of Section 01576 - Waste Material Disposal.

3.04 PROTECTION

- A. Maintain pavement in good condition until completion of Work.
- B. Replace pavement damaged by Contractor's operations at no cost to City.

END OF SECTION