



NO VENTS, OPENING WINDOWS, DOORS OR OTHER OPENINGS INTO A BUILDING, ELECTRICAL EQUIPMENT OR OTHER SOURCES OF IGNITION OR OTHER HEAT GENERATING DEVICES ALLOWED WITHIN THREE FEET (3') OF REGULATOR VENT AND 10 FEET (10') FOR AN EVAPORATIVE COOLER VENT.

CITY OF TOMBALL ENGINEERING & PLANNING DEPARTMENT	
GAS METER LOCATIONS AND CLEARANCE REQUIREMENTS	
APPROVED BY COT:	
ENGINEERING & PLANNING DEPARTMENT EFFECTIVE OCTOBER 2024	
SHEET 001 OF 001	DWG NO: COT GAS-03

CAD FILE PATH: