



TRENCH DETAIL

NOTES:

1. THE GAS PIPE/SLEEVING SHALL HAVE A MINIMUM 24" OF COVER AND A MAXIMUM 36" OF COVER AS MEASURED FROM FINAL GRADE.
2. A MINIMUM OF 12" OF SEPARATION SHALL BE MAINTAINED BETWEEN GAS PIPE AND ALL OTHER UNDERGROUND FACILITIES. MINIMUM SPACING MAY BE REDUCED TO 6" WITH CASING.
3. ENSURE ALL TRENCHES FOR MAINS AND SERVICES ARE PROPERLY BACKFILLED BEFORE GASSING UP FACILITIES.

**CITY OF TOMBALL**  
ENGINEERING & PLANNING DEPARTMENT

**TYPICAL RESIDENTIAL  
SERVICE TRENCH DETAIL**

APPROVED BY COT:

ENGINEERING & PLANNING DEPARTMENT  
EFFECTIVE OCTOBER 2024

SHEET 001 OF 001

DWG NO: COT GAS-06